

From

Engineer-in-Chief, Haryana
Public Health Engineering Department,
Panchkula.

To

All Superintending Engineers,
Public Health Engineering Circles,
Haryana.

All Executive Engineers,
Public Health Engineering Divisions,
Haryana.

Memo No. 21846-916 -PHED/Urban Dated: 11.03.2016

Subject: Development works in unauthorized colonies.

It is intimated that Urban Local Bodies, Haryana vide endst. No. DULB/TP/A2/2015/7101-7102 dated 24.12.2015 conveyed the decision that "Water supply may be provided through stand post /common tanks (not individual connection) irrespective of type of colony. The disposal system for such type of used water may also be provided."

The instructions issued by Director, Urban Local Bodies, Haryana have been further reviewed. It has been decided that Public Health Engineering Department may finalize the location of water resources having sufficient space to generate water @ 135 LPCD, design the pipeline / distribution system to supply drinking water @ 135 LPCD based on location of water sources, prepare the estimate and lay the pipeline accordingly but the cost of water supply source be included in estimate for @ 40 LPCD requirement to supply drinking water @ 40 LPCD per day to supply water through stand posts in unauthorized colonies of Urban areas. The identification of location of water sources having space to generate @ 135 LPCD is required to design the pipeline @ 135 LPCD with respect to location of water source. The above proposal has been approved by Hon'ble Chief Minister on 05.03.2016.

You are, therefore, requested to design the water supply system and ensure to supply drinking water in unauthorized colonies in view of instructions dated 24.12.2015 of Director, Urban Local Bodies, Haryana and decision as stated above.

S. Singh 11/31/2016
Executive Engineer (Urban)
For Engineer-in-Chief, Haryana.
PHED, Panchkula.